

Official Laboratory Report

Report To: LOIS ELLIOTT GRAHAM RS MSA
PO BOX 30817
LANSING MI 49341

Sample ID: LJ27659
Work Order: 01000833_05

System Name/Owner:	PLAINFIELD05370TP100	WSSN/Pool ID:	053700
Collection Address:	5220 WOODFIELD CT NE, GRAND RAPIDS	Source:	TYPE I
Collected By:	MICHAL KOSCIARZ	Site Code:	
Township/Well#/Section:	//	Collector:	Other
County:	Kent	Date Collected:	10/05/2020 10:50
Sample Point:	TP100	Date Received:	10/07/2020 12:10
Water System:	Public System Well	Purpose:	Routine Monitoring

Sample Comment **LJ27659** **Field Reagent Blank was analyzed and acceptable per method requirements.**

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

Per-And Polyfluorinated Alkyl Substances

11CI-PF3OUdS	Not detected	ng/L	2	10/12/2020		EPA 537.1	763051-92-9c
9CI-PF3ONS	Not detected	ng/L	2	10/12/2020		EPA 537.1	756426-58-1d
ADONA	Not detected	ng/L	2	10/12/2020		EPA 537.1	919005-14-4e
HFPO-DA	Not detected	ng/L	2	10/12/2020	370	EPA 537.1	13252-13-6b
NEtFOSAA	Not detected	ng/L	2	10/12/2020		EPA 537.1	2991-50-6
NMeFOSAA	Not detected	ng/L	2	10/12/2020		EPA 537.1	2355-31-9
PFBS	4	ng/L	2	10/12/2020	420	EPA 537.1	375-73-5
PFDA	Not detected	ng/L	2	10/12/2020		EPA 537.1	335-76-2
PFDoA	Not detected	ng/L	2	10/12/2020		EPA 537.1	307-55-1
PFHpA	Not detected	ng/L	2	10/12/2020		EPA 537.1	375-85-9
PFHxA	Not detected	ng/L	2	10/12/2020	400000	EPA 537.1	307-24-4
PFHxS	Not detected	ng/L	2	10/12/2020	51	EPA 537.1	355-46-4
PFNA	Not detected	ng/L	2	10/12/2020	6	EPA 537.1	375-95-1
PFOA	Not detected	ng/L	2	10/12/2020	8	EPA 537.1	335-67-1
PFOS	Not detected	ng/L	2	10/12/2020	16	EPA 537.1	1763-23-1
PFTA	Not detected	ng/L	2	10/12/2020		EPA 537.1	376-06-7
PFTrDA	Not detected	ng/L	2	10/12/2020		EPA 537.1	72629-94-8
PFUnA	Not detected	ng/L	2	10/12/2020		EPA 537.1	2058-94-8

RL: Reporting Limit	mg/L: milligrams / Liter (ppm)	CFU: Colony Forming Unit
MCL: Maximum Contaminant Level	ng/L: nanograms / Liter (ppt)	CAS: Chemical Abstract Service
AL: Action Level	MPN: Most Probable Number	Laboratory Contact: Marlene Kane
Not Detected: Not detected at or above the reporting limit (RL)		

Sample ID: LJ27659

Work Order: 01000833_05

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Kent County Health Dept.
700 Fuller NE
Grand Rapids, MI 49503
616 632-6900**

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane